

Kết quả quan trắc nước thải tự động trung bình 24 giờ tháng 7/2023

Thông số	TSS	Nhiệt độ	Độ màu	COD	pH	Q đầu ra	Amoni	Q đầu vào	DO
Đơn vị	mg/l	°C	Pt-Co	mg/l		m3/h	mg/L	m3/h	mg/L
Ngày									
1/7/2023	15.31	38.92	30.43	24.22	7.82	269.44	0.48	252.07	6.71
2/7/2023	15.31	39.34	30.41	23.57	7.8	274.18	0.49	253.98	6.76
3/7/2023	15.32	39.52	30.4	22.79	7.84	311.46	0.51	255.29	6.79
4/7/2023	17.06	39	31.63	22.78	7.84	383.78	0.49	256.12	6.82
5/7/2023	16.39	39.23	31.11	21.22	7.84	377.45	0.49	257.37	6.85
6/7/2023	16.78	39.13	31.34	19.3	7.81	401.42	0.48	169.74	4.51
7/7/2023	17.75	38.66	32.03	19.72	7.77	425.59	0.47	58.26	1.53
8/7/2023	18.19	37.93	32.4	22.2	7.74	422.76	0.45	57.16	1.5
9/7/2023	17.52	38.29	31.88	20.33	7.68	417.28	0.45	56.62	1.49
10/7/2023	17.93	38.47	32.1	18.24	7.64	426.31	0.47	133.97	2.05
11/7/2023	15.03	38.21	30.04	17.24	7.7	335.61	0.45	255.2	2.95
12/7/2023	14.77	38.24	29.83	16.21	7.69	334.71	0.45	260.13	2.98
13/7/2023	13.24	38.3	28.87	20.14	7.71	268.96	0.46	256.91	2.96
14/7/2023	14.06	38.25	29.55	23.62	7.71	359.3	0.46	245.21	2.9
15/7/2023	14.84	36.37	30.11	24.03	7.71	411.89	0.44	238.12	2.86
16/7/2023	14.03	38.37	29.49	22.4	7.68	400.49	0.5	236.42	2.85
17/7/2023	13.31	38.4	28.94	20.92	7.73	387.59	0.56	234.92	2.84
18/7/2023	15.89	37.37	30.71	19.01	7.73	501.61	0.55	237.84	2.86
19/7/2023	18.19	36.21	32.27	16.9	7.69	606.66	0.49	233.48	2.84
20/7/2023	17.41	36.98	31.9	23.92	7.64	514.95	0.45	241.4	2.88
21/7/2023	16.46	37.64	31.24	24.64	7.63	474.77	0.41	240.57	2.87
22/7/2023	15.49	38.19	30.49	21.82	7.7	463.27	0.4	238.49	2.86
23/7/2023	15.07	38.61	30.11	18.25	7.68	477.28	0.42	247.4	2.91
24/7/2023	14.8	38.82	30.01	21.33	7.83	437.92	0.44	247.09	2.91
25/7/2023	14.56	39.15	29.81	20.3	7.85	437.86	0.44	257.2	2.97
26/7/2023	14.66	39.42	29.87	19.96	7.72	446.14	0.45	259.33	2.98
27/7/2023	14.06	39.75	29.35	16.52	7.67	455.22	0.46	254.36	2.95
28/7/2023	15.24	39.79	30.29	20.54	7.66	466.04	0.45	255.87	2.96
29/7/2023	14.24	39.81	29.67	23.96	7.66	396.82	0.44	253.21	2.94
30/7/2023	14.02	40.1	29.51	23.11	7.66	392.42	0.44	253.82	2.95
31/7/2023	16.76	39.21	31.45	24.09	7.65	488.47	0.43	253.37	2.95
QCVN 40:2011/ BTNMT	40.5	40	50	70	6-9		4.05		